Jordan School District Custodial Services

Water Treatment Boiler Log

School _____

Date	Steam Boiler Tests				Condensate Test		Treatment Added				Quantity on Hand				Comments
	Water Meter	uMhos	Sulfite 2209	Nitrite 2478	pH 3242	uMhos	Sulfite 2209	Nitrite 2478	pH 3242	Other	Sulfite 2209	Nitrite 2478	pH 3242	Other	
		2000 4500	20-60	600-1000	7.5-8.2										